

Originator : NATHAN CROP
Planner : JIMMIE KNAPP
Drawing No :
Equip No/Cat: 2CCE--D 3
Project ID : 2CCE-FAN-1D
Shutdown : N No Shutdown
Ref No :
Schedule Date : 07/05/05
Priority : 3A
Clearance : YES
Tag Request :
Text ID :
Frequency : NOT SCHEDULED
Last Reading : No Reading

Date Completed: _____ Failure Code: _____
Completed By : _____ Signature : _____
Accepted By : _____ Signature : _____

** Delay Codes Legend **

W=Whse C=CrSp T=Tag TL=Tool P=Plan
** Record Time Daily ** Delays

| Step | Job Scope | MN | DY | Safety and Additional Information | Emp No | Date | Hours | Code/Hrs |
|------|--|----|----|--|--------|------|-------|----------|
| 1 | HAVE I&C TECHNICIAN MODIFY UNIT 2 SCBR COMMON MODICON PROGRAM AS NOTED BY NATHAN CROP. ALSO PLACE THE WORDS "CH WTR PUMP TROUBLE" ON THE ASSOCIATED SCBR COMMON ANNUNCIATOR LIGHT. THE NEW INPUT IS 10329 AND THE OUTPUT USED SHOULD BE 00088. 1690.0511 ***** JOB SCOPE: 1. DISCUSS THE WORK TO BE DONE WITH THE AQCS OPERATOR. INFORM HIM OF ANY PROBLEMS WITH ALARMS, CONTROLS, OR INDICATIONS THAT MAY OCCUR AS A RESULT OF THIS WORK. 2. CORRECT ALL PROBLEMS FOUND ON THIS WORK ORDER UNLESS PARTS ARE NEEDED THAT ARE NOT IN THE WAREHOUSE OR A CLEARANCE IS NEEDED TO DO THE JOB SAFELY. 3. MAKE THE MODICON CHANGES AS DESCRIBED ON THE ATTACHED DRAWINGS. 4. CREATE A TRANSPARENT TAPE WITH THE LEGEND "CH WTR PUMP TROUBLE" AND INSTALL IT ON THE SCRUBBER COMMON ALARM WINDOW. 5. SLIDE THE LINKS TO PLACE THE NEW POINT IN SERVICE. 6. PLEASE NOTE ALL PROBLEMS FOUND AND ANY CORRECTIVE ACTION TAKEN TO RETURN THE SYSTEM TO NORMAL OPERATION. | 1 | 1 | ***** SAFETY / ENVIRONMENTAL REQUIREMENTS: A. BE AWARE OF THE ENERGIZED ELECTRICAL CIRCUITS IN THE BACK OF THE CONTROL PANEL, WHERE THE MODICON SYSTEM IS LOCATED. ***** ADDITIONAL INFORMATION: a. SEE THE ATTACHED PACKAGE FROM NATHAN CROP. ALL DRAWINGS THAT HAVE BEEN MODIFIED ARE INCLUDED. b. NATHAN CAN BE REACHED AT EXTENSION 6483. HE SHOULD BE WITH YOU WHEN YOU DO THIS WORK. c. THE ELECTRICIANS HAVE ALREADY BROUGHT IN THE WIRING TO INPUT 10329. THE LINKS ARE SLID OPEN. d. OUTPUT POINT 00088 WILL MAKE THE ALARM LIGHT ON THE ANNUNCIATOR PANEL. THE ANNUNCIATOR PANEL SHOULD BE THE SAME ON BOTH UNIT ONE AND UNIT TWO. | | | | |

** IMPORTANT NOTICE **

YOU ARE RESPONSIBLE FOR YOUR OWN SAFETY AND MUST ENSURE THAT THE REQUIRED PPE IS WORN FOR EVERY JOB YOU ARE DOING. IF YOU HAVE ANY QUESTIONS CONCERNING THE WORK RULES, SAFETY CODES, OR REQUIRED PPE, PLEASE CONTACT YOUR SUPERVISOR.

Job Feedback/Historical Notes:



02-53663-36

IP7013322